

ELECTRICAL EQUIPMENT SERVICE SCHEDULE

[illegible]

Safety switch is to be tested using inbuilt test switch every six months. Every two years the test switch must be tested by our electrician. Please initial in the appropriate square when the check is complete. Please ensure that the electrician signs in the appropriate square following the biennial test.